



SANITARY INSPECTION REPORT

IDENTIFICATION

OWNER INFORMATION

(Complete this section only if different from establishment information)

NAME OF OWNER(S), CORPORATION OR REGISTERED AGENT

Jim Nunn

NUMBER AND STREET

COUNTY

MUNICIPALITY

STATE

ZIP CODE

COMUN. CODE

ESTABLISHMENT INFORMATION

ESTABLISHMENT TRADING NAME

Agnicola

NUMBER AND STREET

COUNTY

MUNICIPALITY

ZIP CODE

TELEPHONE NO.

ESTABLISHMENT STATE LICENSE
NO. (if appl.)

COMUN. CODE

INSPECTION

TYPE OF ESTABLISHMENT

ESTABLISHMENT CODE

☒ RETAIL

☐ OTHER (Specify)

☐

☐

☐ INITIAL INSPECTION

☐ REINSPECTION (other than initial inspection)

GOODS

☐ DESTROYED

☐ EMBARGOED

TIME - (2400 HOURS)

DATE

BEGIN

END

9/14/2015

EVALUATION

☒ SATISFACTORY

☐ CONDITIONALLY SATISFACTORY

☐ UNSATISFACTORY

Remains

OFFICIAL(S)

LOCAL BOARD OF HEALTH

NAME, ADDRESS AND TELEPHONE NUMBER (print)

PRINCETON HEALTH DEPARTMENT
ONE MONUMENT DRIVE
P.O. BOX 390
PRINCETON, NEW JERSEY 08542
609-497-7608

HEALTH OFFICER

Jeffrey C. Grosser

INSPECTING OFFICIAL

INSPECTOR'S NAME AND TITLE

Randy F. Carter
Sr. REHS

INSPECTOR'S SIGNATURE

Randy F. Carter

INSPECTOR'S PERM. REG. NO.

B1805

CONTINUATION SHEET

(for Inspections, Surveys, Audits, etc.)

Name (Individual, Facility, Establishment, etc.)

Agricola

Date

9/16/2015

Municipality

Princeton

Tel., Code or ID No.

609-921-2798

Item

No.

Remarks

8:24-8:30 - Emergency closing for Lower Kitchen Exhaust

Bill Drake, Fire Marshall conducted a complete inspection of the Lower Exhaust Hood & Fire Suppression System and gave approvals to use the Exhaust hood with conditions that the hood cleaning company cleans the ductwork to get the excess grease after a NEW wider bigger hood is put into the duct work in order to facilitate easier access to hard to reach areas.

Approved by Health Dept to use stoves etc. & Exhaust Hood
all areas have been cleaned & sanitized

Remains Satisfactory

Signature of Individual Completing Form

[Signature]

Signature of Owner of Facility, Establishment, etc., if required

[Signature]